

A Technical and Economic Outlook of Ammonia-Based Post-Combustion CO₂ Capture

Peter Versteeg


Advised By Ed Rubin

June 28, 2010


Objectives

- Provide cost and performance numbers that informs energy policy
- Specifically how much carbon capture and sequestration is likely to cost at a full sized power plant.


Ammonia-Based Post-Combustion CO₂ Capture



Ammonia-Based Post-Combustion CO₂ Capture



CO₂ Capture Studies Using Ammonia and Amines




The Baseline Power Plant


- Derived from the 2007 NETL Baseline Report
- Includes amine post-combustion CO₂ capture

Parameter	Value
Plant Location	Midwestern USA
Steam Cycle Type	Supercritical
Coal Type	Illinois No. 6
Coal Flow Rate	74 kg/sec
Gross Power	663 MW
Flue Gas Flow Rate	860 kg/sec
CO₂ Mole Fraction	13.3 %
CO₂ Flow Rate	175 kg/sec
Overall CO₂ Capture	90%
Net Power	546 MW

Ammonia Based CO₂ Capture Model




CO₂ Capture vs. NH₃ Concentration




Series Labels: Solvent Flow Rate into the Absorber (kg/sec)

NH₃ Slip vs. NH₃ Concentration



Series Labels:
Solvent Flow Rate
into the Absorber
(kg/sec)

Solids Flow vs. NH₃ Concentration



CO₂ Capture System Designs

Key Variable	Low Conc. Design	High Conc. Design
NH ₃ Concentration	6.5%	21.0%
Flow Rate (kg/sec)	3400	500
Overall CO ₂ Capture	90%	90%
NH ₃ Slip	1930 ppm	2240 ppm
Solids	Do Not Occur	60 wt %

Overall Model Performance Summary


	Low Conc.	High Conc.	Amine*
Potential Power Available (MW)	827.6	827.6	827.6
Auxiliary Steam Load (MW)	174.5	109.1	164.3
Steam Turbine Power (MW)	653.0	718.5	663.3
Auxiliary Electrical Load (MW)			
Base Plant (MW)	49.0	49.0	49.0
CO2 Capture System (MW)	116.8	90.6	21.3
CO ₂ Compression (MW)	16.4	16.4	46.9
Plant Net Power (MW)	470.9	562.6	546.0
Plant Efficiency (% HHV)	23.5%	28.1%	27.2%
Energy Penalty (%)	40.0%	28.3%	30.6%

* NETL 2007 Baseline Report

Key Performance Variables with Uncertainty

Parameter	Units	Nominal	Distribution Function
Solvent Chilling Loads			Uniform(-25%,+25%)
Auxiliary Steam Loads			Uniform(-25%,+25%)
ΔP Across the DCC2 and CO ₂ Absorber	Psi	4	Uniform(2, 6)
Chiller Electrical Use, 45°F Water Product	kW/ton	0.47	Triangular(0.47, 0.47, 0.50)
Chiller Electrical Use, 37°F Water Product	kW/ton	0.55	Triangular(0.50, 0.55, 0.60)
CO ₂ Compression, 30 bar to 152 bar	kWh/kg CO ₂	0.029	Triangular(0.026, 0.03, 0.032)
DCC2 Chilling Loads	1000 tons/hr	32.2	Triangular(29.0, 32.2, 35.4)

Ammonia System Energy Penalty



Overall Model Cost Summary


	Low Conc.	High Conc.	Amine*
Base Plant	1150.3	1169.0	1166.2
CO2 System	607.6	408.30	394.0
Plant Total Capital Requirement	1757.9	1575.9	1560.0
CO ₂ TS&M O&M/Year	13.7	13.7	13.7
Balance of Plant O&M/Year	116.7	116.7	116.7
Total O&M Costs/Year	130.4	130.4	130.4
Capital Required (\$/kW-net)	3733.3	2790.7	2857.0
Revenue Required (\$/MWh)	141.6	109.5	118.7

* IECM, CF = 75%

Overall Cost Results with Uncertainty

Parameter	Unit	Nominal	Distribution Function
General Facilities Capital	%PFC	1.6	Triangular(1, 1.6, 2)
Engineering & Home Office Fees	%PFC	9.4	Triangular(7, 9.4, 12)
Project Contingencies	%PFC	16.4	Triangular(10, 16.4, 20)
Process Contingencies	%PFC	4.7	Triangular(2, 4.7, 10)
Ammonia Cost (28 wt% delivered)	\$/ton	129.4	Uniform(116, 142)
Cooling Equipment Costs	\$/ton cooling	441.2	Uniform(309, 573)
IECM Based Equipment Costs	\$		Uniform(-30%, +30%)
Aspen Icarus® Equipment Costs	\$		Uniform(-40%, +40%)
Power Plant Fixed Charge Factor	--	0.175	Uniform(0.16,0.19)
Power Plant Levelized Capacity Factor	--	0.75	Weibull(8.5, 0.81)

Ammonia System Revenue Required



Summary

- The plant with high concentration ammonia-based CO₂ capture was found to have an energy penalty 2-3 percentage points lower and a levelized cost 9 \$/MWh lower than the plant with amine-based CO₂ capture.
- The stochastic results suggested better performance and lower costs

Plant Configuration	Energy Penalty	Plant Efficiency	Capital Required (\$2007/kW-net)	Revenue Required (\$2007/MWh)
Without CCS	--	39%	1460	61
Amine	31%	27%	2860	119
Low Conc. NH ₃	40%	24%	3670	140
High Conc. NH ₃	28%	28%	2790	110

Conclusion/Limitations

- High concentration ammonia-based CO₂ capture performs well against amine-based CO₂ capture and could lower the costs of CO₂ mitigation in the electric power sector
- This analysis could be refined and extended with improved thermodynamic models, more detailed simulations of process components, heat integration, and more detailed/current vendor cost estimates

Acknowledgements



Natural Sciences and
Engineering Research
Council of Canada

Conseil de recherches
en sciences naturelles et
en génie du Canada

Canada