

Supplementary Information: Deploying gas power with CCS: The role of operational flexibility, merit order and the future energy system

Matthias A. SCHNELLMANN*¹, Chi Kong CHYONG², David REINER², Stuart A. SCOTT¹

¹ Department of Engineering, University of Cambridge, Trumpington Street, Cambridge, CB2 1PZ, United Kingdom.

² Energy Policy Research Group, Judge Business School, University of Cambridge, Trumpington Street, Cambridge, CB2 1AG, United Kingdom.

*Corresponding Author, mas227@cam.ac.uk, +44 (0) 1223 748595

1. Energy Penalty associated with carbon capture

the energy penalty and it was assumed to be made up of three contributions (Lin et al., 2012). The first was the heat required to raise the temperature of the solvent stream to the stripper temperature and the second was the heat required to balance the enthalpy of reaction associated with regenerating the solvent and releasing the CO₂ in the stripper. The total heat required per mole of CO₂, Q , was given by

$$Q = \frac{m_{\text{solvent}}(C_p \Delta T + \Delta q_{\text{CO}_2} \Delta h_{\text{CO}_2})}{m_{\text{CO}_2}} \quad 1$$

where C_p is the heat capacity of the solvent, m_{solvent} is the molar flowrate of solvent, Δq_{CO_2} is the change in CO₂ loading of the solvent between its rich and lean states, Δh_{CO_2} is the heat of absorption of CO₂ and m_{CO_2} is the molar flow rate of CO₂. ΔT is the change in temperature required, assumed to be 10 K, accounting for the fact that there is heat exchange between the rich and lean solvent streams. This thermal energy was supplied by diverting steam from the power cycle. The resulting decrease in electrical output is taken to be:

$$E = 0.75\eta Q \quad 2$$

where the factor of 0.75 is the efficiency of the turbine (Freeman et al., 2009) and η is the Carnot efficiency of extracted steam, given by:

$$\eta = 1 - \frac{T_C}{T_H} \quad 3$$

where T_C and T_H are the temperatures of the environment (298 K) and of extracted steam (623 K) respectively. The final contribution was the electrical energy required to compress the CO₂ to 150 bar, assumed to be 15 kJ/mol CO₂ (House et al., 2009). The contribution of electrical energy required to pump the solvent between the absorber and the stripper was found to be negligible.

Freeman, S.A., Dugas, R., Van Wagener, D., Nguyen, T., Rochelle, G.T., 2009. Carbon dioxide capture with concentrated, aqueous piperazine. Energy Procedia 1, 1489–1496. doi:10.1016/J.EGYPRO.2009.01.195

- House, K.Z., Harvey, C.F., Aziz, M.J., Schrag, D.P., 2009. The energy penalty of post-combustion CO₂ capture & storage and its implications for retrofitting the U.S. installed base. doi:10.1039/b811608c
- Lin, L.-C., Berger, A.H., Martin, R.L., Kim, J., Swisher, J.A., Jariwala, K., Rycroft, C.H., Bhowm, A.S., Deem, M.W., Haranczyk, M., Smit, B., 2012. In silico screening of carbon-capture materials. *Nat. Mater.* 11, 633–641. doi:10.1038/nmat3336